

Brampton Memorial Arena

Magnetic Water Conditioning System Evaporative Condenser



BEFORE

- Magnets installed November 4, 1998
- No chemical treatment program in place
- Hard scale crystals on surface of ammonia tubes, restricting optimum heat transfer



AFTER

1998/99 Winter Season

- Ammonia tubes are cleaner with significantly less scale overall
- Texture of solids is softer and more like "powder"
- Much of remaining solids can be cleaned with a garden hose